

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/21/2015  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>15C0001174</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - METRO SPECIALTY SURGERY CENTER</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R 10/16/2015</b>	
NAME OF PROVIDER OR SUPPLIER  <b>METRO SPECIALTY SURGERY CENTER LLC</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>200 MISSOURI AVE, BLDG 18 JEFFERSONVILLE, IN 47130</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification survey conducted on 07/30/15 was conducted by the Indiana State Department of Health in accordance with Department of Health in accordance with 42 CFR 416.44(b).</p> <p>Survey Date: 10/16/15</p> <p>Facility Number: 012244 Provider Number: 15C0001174 AIM Number: NA</p> <p>At this PSR survey, Metro Specialty Surgery Center LLC was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 20, New Ambulatory Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors.</p> <p>Quality Review completed on 10/20/15 - DA</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.